

Suite 200, P/Bag X025
Lynnwood Ridge, 0040
South Africa

115 Excelsior str
Meyerspark
Pretoria
South Africa

Gerrit: 082 5781152
Tel: (012) 803 6046
International: (27 12)803 6046
Fax: (086) 680 7256
e-mail: gerrit@aquadoc.co.za
VAT Nr. 42 601 581 02

Date: 02/09/2013

JT:4532

REPORT ON WATER ANALYSIS

Submitter: GOURMET ICE (Pty) Ltd
Attention: Adéle
Address: P.O. Box 14504, Sinoville, 0129
Tel: 012 329 1194 Fax: 086 512 1680 Cell: 072 1672104
e-mail: sales@gourmetice.co.za


Description: 1 x water sample
Determination of water quality: Filtration System Tap.

Date received: 19/08/2013

Date completed: 30/08/2013

Order No: Adéle

Contaminants			
Determinant	Unit	Water Sample	SANS 1657:2011 Bottled Water subterranean origin
			Amount permissible
Heterotrophic plate count	/ml	49	<100
Total coliform bacteria	/ 100ml	0	Absent
Faecal coliform bacteria	/ 100ml	0	Absent
Limits for specific substance			
Substance	Unit	Water Sample	Limits
Copper	mg/l	<0,025	1.0 mg/l
Manganese	mg/l	<0,025	0.5 mg/l
Cadmium	mg/l	<0,005	0.01 mg/l
Lead	mg/l	<0,020	0.01 mg/l



**Suite 200, P/Bag X025
Lynnwood Ridge, 0040
South Africa**

**115 Excelsior str
Meyerspark
Pretoria
South Africa**

**Gerrit: 082 5781152
Tel: (012) 803 6046
International: (27 12)803 6046
Fax: (086) 680 7256
e-mail: gerrit@aquadoc.co.za
VAT Nr. 42 601 581 02**

Quality	Units		Limits (if applicable)
Zinc	mg/l	<0,025	5.0 mg/l
Iron	mg/l	<0,025	2.0 mg/l
Fluoride	mg/l	<0,2	1.0 mg/l calculated as F
Nitrate	mg/l	2,6	10 mg/l calculated as N
pH	pH units	7,2	4,0 – 9,5
Colour	mg/l Pt	12	Maximum 20 mg/l Pt
Turbidity	NTU	0,07	Maximum 1 NTU
Electrical Conductivity at 25°C	mS/m	37	
Calcium as Ca	mg/l	2	
Magnesium as Mg	mg/l	<2	
Sodium as Na	mg/l	82	
Chloride as Cl	mg/l	22	
Sulphate as SO ₄	mg/l	21	
Total Hardness	mg/l	<13	Very soft

Remarks:

This report relates only to the samples as actually received by AQUADOC Analytics cc. This Company does not accept responsibility for any matters arising from the further use of these results.



Gerrit Idema